

Kanningarnr		V219-00112-1	V219-00112-2	V219-00112-3
Sýnislag		Drekkivatn	Rávatn	Drekkivatn
Kundasak				
Kundamerki		Syðrugøta	Syðrugøta	Norðragøta
Sýnið tikið		190219	190219	190219
100702	Enterokokkar, 37°C /100 ml	<1	<1	<1
105100	Lagt inn mikro	+	+	+
111610	Totalkim TGA 22°C /ml	1 est	300	1 est
112502	E.coli Colil-18kvant /100 ml		<1	
113202	Kolif.Colil-18,kvant /100 ml		11	
132102	Kolif. vatn ISO 1/2 /100 ml	<1		<1
132202	E.coli vatn ISO 2/2 /100 ml	<1		<1
133102	Cl.perfring.vatn,TSC /100 ml	<1		<1
152700	Felags avg.gjald (M)	+		
201100	Kanningar Eurofins			
205100	Góðkent kemi			
205600	Felags avg.gjald (K)	+		
210200	Litur (V) mg Pt/l	<2	<2	<2
211628	Leiðingarevni (V) mS/m	9,9	10	9,6
211900	pH (V)	6,9	7	6,9
212830	Turbiditet (V) NTU	0,17	0,3	0,38
217541	Ammonium (V) mgN/l	<0,014		<0,014
224100	Luktur	Eingin		Eingin
232227	Al(ICP-MS) (V) mg/l			
232315	Sb (ICP-MS) (V) µg/l			
232415	As (ICP-MS) (V) µg/l			
232515	Pb (ICP-MS) (V) µg/l			
232727	B (ICP-MS) (V) mg/l			
232815	Cd (ICP-MS) (V) µg/l			
232915	Cr (ICP-MS) (V) µg/l			
233027	Fe (ICP-MS) (V) mg/l			
233115	Cu (ICP-MS) (V) µg/l			
233215	Hg (ICP-MS) (V) µg/l			
233327	Mn (ICP-MS) (V) mg/l			
233415	Ni (ICP-MS) (V) µg/l			
233515	Se (ICP-MS) (V) µg/l			
233627	Na (ICP-MS) (V) mg/l			
290200	Nitritt mg/l			
290300	Nitrat mg/l			
290400	Klorid mg/l			
290500	Flourid mg/l			
290600	Sulfat mg/l			
290700	Cyanid µg/l			

V219-00112-4 V219-00112-5 V219-00112-6

Rávatn

Drekkivatn

Rávatn

Norðragøta

Leirvík

Leirvík

190219

190219

190219

<1

<1

<1

+

+

+

<1

<1

260

1

<1

2

46

<1

<1

<1

<2

<2

5

9,6

12,9

8,8

6,9

6,9

7

<0,1

<0,1

0,35

<0,014

Eingin

